

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING NO. 7135-0476:123 Page 1 of 1

CATEGORY: Audible Devices

LISTEE: Harrington Signal Inc., 2519 4th Avenue, Moline, IL 61265
Contact: Andrew Keller (309) 762-0731 FAX (309) 762-8215

DESIGN: Model 460 electronic horn. Units may be followed by suffixes R, *W or BG to designate color. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, electrical rating and UL label.

APPROVAL: Listed as audible devices for use with separately listed compatible fire alarm control units and visual signal appliances.

If this appliance is required to produce a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1993 Edition, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

NOTE: Formerly 7135-0811:109 (Transferred from Federal Signal Corp.)

10-09-98



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 23, 2004

*Listing Expires **June 30, 2005***

Authorized By:

**DIANE K. AREND, Senior Deputy
Program Manager**